



Ingeniería Energética

ISSN: 1815-5901

Instituto Superior Politécnico José A. Echeverría.Cujae

de Oliveira, Vinicius; Vilela Ferreira, Duan; Vilela Ferreira, Tarso
Un estudio sobre la anatomía de las pérdidas en la distribución de energía eléctrica
Ingeniería Energética, vol. XLIII, núm. 1, 2022, Enero-Abril, pp. 14-23
Instituto Superior Politécnico José A. Echeverría.Cujae

Disponible en: <https://www.redalyc.org/articulo.oa?id=329170676002>

- Cómo citar el artículo
- Número completo
- Más información del artículo
- Página de la revista en redalyc.org

redalyc.org

Sistema de Información Científica Redalyc
Red de Revistas Científicas de América Latina y el Caribe, España y Portugal
Proyecto académico sin fines de lucro, desarrollado bajo la iniciativa de acceso
abierto



TEORICO EXPERIMENTAL

A Study on the Anatomy of Losses in Electric Energy Distribution

Un estudio sobre la anatomía de las pérdidas en la distribución de energía eléctrica

Vinicius de Oliveira¹, Duan Vilela Ferreira², Tarso Vilela Ferreira^{1,*}

¹Federal University of Sergipe. Graduate Program of Electrical Engineering. São Cristóvão, Sergipe, Brasil.

² Independent consultant.

*Corresponding author: tarso@dee.ufcg.edu.br

Recibido: 2 de mayo del 2021 Aprobado: 20 de agosto del 2021

Licencia de uso y distribución Creative Commons Reconocimiento-No Comercial 4.0 Internacional 

RESUMEN/ ABSTRACT

Non-technical losses represent 7,3% of the total energy distributed in Brazil. The correlation between socioeconomic indicators and losses suggests that the highest concentrations of fraudsters are in regions where the population has low purchasing power and reduced educational instruction. This work carried out observations in 45 distribution circuits, in order to collect information on irregularities in energy consumption. In order to characterize the anatomy of losses in these locations, crossings were carried out between different variables. The relationships were investigated using Pearson's correlation tests, in addition to being graphically represented. The results indicate, that the greater the number of customers in the circuit, the lower the loss rate. It was also revealed that centralized circuits have lower losses than borderline ones. Finally, it appears that the percentage of anomalies tends to systematically decrease within a period of 6 to 11 years after the application of measures to combat and prevent losses.

Keywords: Non-technical loss; energy theft; loss anatomy; graphic representations; Pearson's correlation coefficient.

Las pérdidas no técnicas representan el 7,3% del total de energía distribuida en Brasil. La correlación entre los indicadores socioeconómicos y las pérdidas sugiere que las mayores concentraciones de estafadores se encuentran en regiones donde la población tiene un bajo poder adquisitivo y una instrucción educativa reducida. En este trabajo se realizaron observaciones en 45 circuitos de distribución con el fin de recopilar información sobre irregularidades en el consumo de energía. Para caracterizar la anatomía de las pérdidas se realizaron cruces entre diferentes variables. Las relaciones se investigaron mediante las pruebas de correlación de Pearson, además de estar representadas gráficamente. Los resultados indican que cuanto mayor es el número de clientes en el circuito, menor es la tasa de pérdidas. También se reveló que los circuitos centralizados tienen menores pérdidas que los periféricos. Finalmente, parece que el porcentaje de anomalías tiende a disminuir sistemáticamente en un período de 6 a 11 años después de la aplicación de medidas para combatir y prevenir pérdidas.

Palabras clave: Pérdida no técnica; robo de energía; anatomía de la pérdida; representaciones gráficas; coeficiente de correlación de Pearson.

INTRODUCTION

The loss of electrical energy is present in the entire electrical power system (EPS), from generation to distribution. Losses are characterized by the energy produced but not traded, and they are classified into Technical Losses (TL) and Non-Technical Losses (NTL) [1]. The knowledge of the level of energy losses and their characteristics are crucial to assess the operating condition of the network, the efficiency of energy supply and the effectiveness of actions aimed at reducing losses.

Cómo citar este artículo:

Vinicius de Oliveira y Tarso Vilela Ferreira. A Study on the Anatomy of Losses in Electric Energy Distribution. 2022, vol. 43, n. 1, enero/abril. ISSN:1815-5901.

Sitio de la revista: <http://rie.cujae.edu.cu/index.php/RIE>

Most energy distribution companies in developing countries have high rates of energy losses due to the share of NTL. The NTL in these companies can represent up to 40% of the total generation capacity. The poor infrastructure in these countries makes it difficult to detect and control the potential causes of NTL. Losses affect the quality of supply and the electricity tariff paid by regular customers [2].

Specifically, high rates of NTL activities have been reported in most developing countries in Southeast Asia, which include Malaysia, Indonesia, Thailand, Myanmar and Vietnam [3]. In the light of this problem, other developing countries, such as Bangladesh, India, Pakistan and Lebanon, have an average loss rate between 20% and 30% [4-5]. The problem of NTL is not only faced by the least developed countries in regions of Asia and Africa, but also by developed countries such as the United States of America and the United Kingdom [3]. In [6], total loss rates between 6,57% and 12,36% of the total injected energy in Poland are detailed, as a result of the variation in NTL directly influenced by investment in infrastructure. Transmission and distribution losses worldwide are greater than the total installed generation capacity in countries such as Germany, UK and France [2]. It is estimated that NTL cost distribution companies worldwide approximately US\$96 billion per year [7].

In Brazil, in 2020, NTL represented 7,3% of the total energy injected into the system, which is equivalent to 37,9 TWh at a cost of 8,6 billion reais (about US\$ 1,7 billion) considering the average price of energy from the tariff processes [8]. Given the above, identifying the problems that cause NTL in electric energy distribution circuits arouses the interest of both academy and companies. In [2], factors that influence illegal energy consumption are reported, such as: price, illiteracy rate, unemployment rate, among others. In the literature, there are frequent works that propose the development of computational models to detect fraudulent consumers [9-11]. However, it is difficult to find studies based on real data, without biases or filters, capable of identifying common characteristics of distribution circuits with high loss rates.

Thus, this article deals with a case study, which proposes to analyze information collected in circuits in a Brazilian city, based on observations carried out under three circumstances. The first one carried out before the application of measures to combat NTL, the second carried out right after the interferences, and the last one reflects the current state of each circuit. The time interval between the second and the last information collection vary from 6 to 11 years. The analysis of these observations aims to characterize the anatomy and involution of losses in these regions.

In the next session, concepts about energy losses and Pearson's correlation test are presented. The methodology applied in the data analysis is described below. Afterwards, there is the session that will present the results, and then, the conclusions of the work.

MATERIALS AND METHODS

Energy Losses

Global Energy Losses can be defined as electrical energy generated that travels through transmission lines and distribution networks, but which is not commercialized, either for commercial or technical reasons [10, 12, 13].

Technical Losses (TL) are inherent to the process of energy transport, transmission and distribution, and consist mainly of energy dissipation caused by the physical properties of electrical components, related to the substation, the transformer and the line [14]. As presented in [15], the resistive losses of primary feeders, distribution transformer, secondary network, service branch and energy meters are included in this context. According to [1], technical losses are inevitable, however they can be reduced with the development of new technologies, and with predictive, preventive and corrective maintenance.

Non-Technical Losses (NTL), also called commercial losses, are caused by the lack of billing of part of the distributed energy [14]. In [10], some types of NTL are presented: energy theft, supply fraud, meter failures and reading errors. In a broad context [16], they define fraud as the dishonest or illegal use of electricity equipment or services with the intention of preventing correct billing. According to [17], energy theft is characterized by clandestine connections, direct deviations from the network, without any form of charging, while energy fraud occurs due to tampering with the metering system, which causes errors in charging for energy consumed. Measuring equipment failures are caused by the deterioration of the meter's internal instruments, which in turn cause an incomplete record of consumed energy [18]. According to [19], billing errors are caused by the inefficiency of the concessionaires' commercial system. In [16], they highlight that errors occur during the reading collection process or due to systemic failures during billing.

While the TL are calculated by modeling techniques, the NTL are determined by the difference between the total losses in the distribution and the PT [19-22].

NTL caused by illegal consumers connected to the distribution network, affect the quality of the energy supplied, cause overload, and infer the electricity tariff of regular consumers [2]. In addition, clandestine electricity connections can cause electric shocks and fires, which compromise the safety of electricity services. According to [1], the impact of the NTL on the electricity tariff passed on to the consumer is dimensioned by means of regulatory values obtained from the concessionaires' efficiency criteria. However, distributors that do not meet the regulatory limit for NTL are penalized with a reduction in the tariff transfer. To avoid penalties, optimize revenues and improve energy supply conditions, concessionaires must promote efficient actions to combat NTL.

There are many tools for finding, detecting and controlling NTL. Some mechanisms were presented in [23], such as smart metering, telemetry monitoring, physical inspection and management methods. In countries, where resources are scarce, and smart grid technology is far from reality, the installation of meters along feeders for energy balance allows to accurately estimate NTL [24]. These balances consist of comparing the total energy consumed (measured and billed) by customers, with the total energy generated or delivered to distribution substations [19]. The difference between the energy measured at the feeder and the energy billed by the utility, plus TL, indicates the volume of NTL.

Pearson Correlation Coefficient (*r*)

Pearson's correlation coefficient is a measure of association widely used in different areas of scientific research [25]. For [26], correlation refers to the linear relationship between variables, so that the correlation coefficient is a measure of the association between two numerical variables. In [27], it was stated that a correlation measures the direction and strength of the linear relationship between two quantitative variables.

Pearson's correlation coefficient ranges between - 1 and 1. The sign indicates the direction of the correlation (negative or positive) while the value indicates the magnitude. The closer to 1, the stronger the level of linear association between variables [28]. In table 1, interpretations of the correlation coefficient presented in [29-31] are compared.

Table 1. Comparative between Practical Rules for Interpreting the Correlation Coefficient [29-31]

Correlation Interpretation	Size of Correlation		
	Cohen,1998	Dancey and Reidy, 2006	Mukaka, 2012
Very High	–	–	0,90 to 1,00
High	0,50 to 1,00	above 0,70	0,70 to 0,90
Moderate	0,30 to 0,49	0,40 to 0,60	0,50 to 0,70
Weak	0,10 to 0,29	up to 0,30	0,30 to 0,50
Negligible	–	–	0 to 0,30

To calculate the Pearson correlation coefficient between the variables *x* and *y*, equation (1), below is used:

$$r = \frac{\sum_{i=1}^n (x_i - \bar{x})(y_i - \bar{y})}{\sqrt{[\sum_{i=1}^n (x_i - \bar{x})^2][\sum_{i=1}^n (y_i - \bar{y})^2]}} \quad (1)$$

Where *x_i* and *y_i* are the values of the *i*th individual.

Both the mean and the variance play a central role in estimating this coefficient. Based on [27], this work highlights two conditions that must be satisfied for Pearson's correlation analysis. The first states that to estimate Pearson's correlation, all variables must be discrete and/or continuous quantitative. The other announces that the coefficient is affected by the presence of conflicting values, known as outliers, which can exaggerate or reduce the intensity of the relationship, so the test is inadequate when the study variables are not normally distributed.

Therefore, to apply the correlation test, it must be verified whether the observed values are normally distributed (N (*μ*, *σ*)). This assumption is especially important in small samples. This is because, from the Central Limit Theorem, it is known that the as number of observations increases, the distribution of sample approaches the normal curve, regardless of the data distribution format in the population [32].

There are different tests to estimate the normality of data distribution. In this study, the Kolmogorov-Smirnov (K-S) test was chosen due to its applicability, without restriction to small samples. The quantile values of the test statistic distribution are tabulated and can be found, for example, in [33].

It is important to note that the Pearson's coefficient does not refer to a proportion, nor does it represent the proportional strength of a relationship [25].

Methodology

To carry out the study, initially, observations were made in 45 circuits in needy areas, which add up to more than 5 000 consumers altogether, in order to collect information on irregularities in energy consumption.

The diagnoses of each circuit contemplate three distinct moments: the first carried out before the application of actions to combat the NTL, the second carried out soon after the interventions and the last, prepared in 2021, reflects the current state. Intervals between analyses vary from 6 to 11 years according to the intervention in each circuit.

Then, all observations made are consolidated in a database, which undergoes a systematic verification process in search of any errors that could interfere with the study.

In the scope of the research, energy balances were carried out to measure the percentage of loss of each circuit. In order to characterize the anatomy of losses in these locations, crossings were performed between different variables, such as:

- Loss rate;
- Number of clandestine consumers;
- Volume of self-reconnected customers (defaulting customers irregularly connected to the electricity grid);
- Number of units with internal measuring equipment;
- Number of damaged meters;
- Stock of disconnected customers;
- Number of posts with illegal connections.

The relationships were investigated using Pearson's correlation tests and graphically represented. Prior to the calculation of the Pearson's correlation coefficient, the K-S test was applied in order to certify that the variables are normally distributed at 5% significance level α for the p-value limit, and sample number (n) equals to 45. At this point, the presence of outliers is observed and treated when necessary.

The next step of the adopted methodology was to carry out data crossing with the aid of graphical representations, in order to collect characteristics relevant to losses. In this regard, histograms were used. As a result of this study, relationships capable of pointing out the most significant attributes for losses in these locations were obtained.

RESULTS AND DISCUSSION

Given the nature of the research, the relationship between the variables was first analyzed using Pearson's correlation tests, then graphical representations of the relationships were presented more prominently.

Pearson Correlation Coefficient (r)

The evaluation of the relationships between the variables, through the Pearson's correlation test, portraying losses before and after the application of structural measures to prevent and combat losses, indicates a strong correlation between the percentage of loss reduction and the percentage of losses before the application of NTL combat actions ($r = 0,923987$). This note indicates that the greater the loss rate of the circuit, the greater the reduction (as intuitively expected). Also for this scenario, there is a moderate correlation ($r = 0,676776$) between the number of reconnections carried out in the circuits and the loss rate after the interventions, emphasizing the importance of debt negotiation for the reconnection process, which means curbing irregular energy consumption. Other issues also raised are the moderate correlations between the replacement of meters and the execution of shielding services ($r = 0,668840$), and performance of measurement externalization ($r = 0,691469$), highlighting the need for associated action for these measures.

In the analysis of the variables that represent the current state of the circuits, the applied correlation test showed coefficients of less than 0,5 between the current loss rate and number of irregularities (clandestine, self-reconnected, internal measuring equipment and damaged meters), indicating a correlation weak. The correlation coefficients between the current loss rate and each variable can be seen in table 2.

Table 2. Pearson's Correlation Coefficient between the Current Loss Rate and Other Variables

Variable	Coefficient (r)	Classification
Clandestine consumers	0,195260	Negligible
Self- reconnected	0,401207	Weak
Internal measuring equipment	0,258365	Negligible
Damaged meters	0,279925	Weak

Thus, it is concluded that there is no preponderant anomaly directly correlated with the percentage of losses, which reinforces the need to associate actions, to actually achieve control over commercial losses of electricity.

Graphic Representations

With the crossing of data and graphical representations, relationships capable of extracting the most significant attributes for losses in these locations were obtained. The results indicate, among other findings, that the greater the number of consumers in the circuit, the lower the loss rate (figure 1).




Fig. 1. Percentage of circuits by loss rate range categorized according to the number of consumers.

This relationship is also valid when we observe only the number of standardized consumers (regular customers with standardized measurement) per circuit (figure2).




Fig. 2. Percentage of circuits by loss rate range categorized according to the number of standardized clients.

It was also observed that 82% of the centralized circuits (located in the central area of the neighborhood) have losses of less than 30%, while 64% of the borderline ones (located in the border area) have losses greater than 30%. This relationship can be seen in figure 3, which indicates the number of circuits per loss range and region, and figure 4, which indicates the percentage of circuits with per geographic region and loss limit below and above 30%.




Fig. 3. Number of circuits observed by region, categorized into loss range.



Fig. 4. Percentage of circuits by loss rate range categorized by region.

In borderline circuits, the relationship that deserves visibility is the connection between the percentage of disconnected customers and the percentage of circuit losses. In this case, the lower the percentage of defaulting customers effectively disconnected, the greater the percentage of self-reconnected consumers, consequently the higher the percentage of circuits with high loss rates. This information reveals how the presence of disconnected units in this region can influence the NTL rate (figure 5).




Fig. 5. Percentage of circuits by loss rate range categorized according to the percentage of disconnected customers in circuits in the bordering region.

In circuits located in the central region, the highlight is the association between the number of clandestine connections and the percentage of commercial losses, revealing that the higher the percentage of clandestine connections, the higher the percentage of circuits with high loss rates (figure 6). Therefore, in this area, it is important to indicate and regularize clandestine connections to monitor and control of commercial losses.




Fig. 6. Percentage of circuits by loss rate range categorized according to the percentage of clandestine.

Also in the comparison of irregularity rates between regions, it is highlighted that the percentages referring to structures with illegal connections, self-reconnected customer, internal metering, damaged meter and clandestine connection, are higher in neighboring electrical distribution circuits. In turn, the stock of consumer units disconnected (turned off) is greater in central circuits, which suggests that in this region there is a natural inhibition of the occurrence of self-reconnection by the customer. Rates for each region are shown in table 3.

Type	Region	
	Centralized	Borderline
Post with illegal connections	25%	38%
Disconnected customers	8%	7%
Self- reconnected	4%	7%
Internal measuring equipment	5%	6%
Damaged meters	5%	8%
Clandestine consumers	2%	4%

Finally, it appears that the percentage of anomalies tends to systematically decrease within a period of 6 to 11 years after the application of measures to combat and prevent losses. These rates are compared in table 4.

Table 4. Percentage of Irregularities by Type and Age Range of Interventions

Type	Age Range		
	6 to 7 years	8 to 9 years	10 to 11 years
Post with illegal connections	38%	26%	25%
Disconnected customers	10%	8%	4%
Self- reconnected	4%	4%	2%
Internal measuring equipment	7%	6%	3%
Damaged meters	6%	5%	6%
Clandestine consumers	5%	3%	1%

The percentages referring to the number of structures with illegal connections, stock of disconnected customers, self-reconnected, internal metering equipment and clandestine consumers, decrease in the period from the sixth to the eleventh year after the structuring measures are applied in a coordinated manner to combat commercial losses, regardless of the region in which the circuit is located. Although this effect may be credited to NTL combat actions, consumers education may also have an important role. Another relevant indicator refers to the percentage of customers with damaged meters, which remains stable over the years, making it necessary to recurrently apply the meter replacement measure.

CONCLUSION

The knowledge of the level of energy losses and their characteristics are essential to assess the operating condition of the network, the quality of energy supply, and the effectiveness of actions aimed at reducing losses.

In this article, the state of 45 electrical energy distribution circuits, which add up to more than 5 000 consumers altogether, were observed in the field, for which energy balances were carried out to measure the percentage of losses. In order to characterize the anatomy of losses in these locations, crossings were performed between different variables. The relationships were investigated using Pearson's correlation tests and graphical representations.

The conclusions indicate that there is no preponderant anomaly directly correlated with the percentage of losses, which reinforces the need to associate actions to actually achieve control over commercial energy losses. In addition, they point out that the greater the number of customers on the circuit, the lower the loss rate, and reveal that 82% of the centralized circuits (located in the central area of the neighborhood) in the study have losses of less than 30%, while 64% of the borderline ones (located in the bordering part) have losses greater than 30%, which indicates greater occurrences for this region. Finally, it appears that the percentage of anomalies tends to systematically decrease within a period of 6 to 11 years after the application of measures to combat and prevent losses.

Thus, the research highlights the importance of knowledge about the multiple variables that describe the anatomy of PNTs in electrical distribution circuits, to support decisions about which actions should be taken to prevent and combat losses.

REFERENCES

- [1]. HAMMERSCHMITT B. K., *et al.* "Non-Technical Losses Review and Possible Methodology Solutions". In: 2020 6th International Conference on Electric Power and Energy Conversion Systems (EPECS); Istanbul, Turkey; 2020; p. 64-68, DOI: 10.1109/EPECS48981.2020.9304525. Disponible en: <https://ieeexplore.ieee.org/abstract/document/9304525>
- [2]. DEPURU S., *et al.* "Measures and setbacks for controlling electricity theft". In: North American Power Symposium 2010; Arlington, TX; 2010; p. 1-8, DOI:10.1109/NAPS.2010.5619966. Disponible en: <https://ieeexplore.ieee.org/document/5619966>
- [3]. NIZAR A. H. and Dong Z. Y. "Identification and detection of electricity customer behavior irregularities" In: Proc. of IEEE/PES Power Systems Conference and Exposition; Seattle, Washington, United States; Mar.15-18; 2009; p. 1-10. Disponible en: <https://ieeexplore.ieee.org/abstract/document/4840253>
- [4]. NAGI J., *et al.* "Nontechnical loss detection for metered customers in power utility using support vector machines". IEEE Trans. Power Del. 2010; vol. 25, n. 2, p. 1162-71. Disponible en: <https://ieeexplore.ieee.org/document/5286297>
- [5]. NIZAR A. H., DongZY, and Wang Y. "Power utility nontechnical loss analysis with extreme learning machine model". IEEE Trans. PowerSyst. 2008; vol. 23, n. 3, p. 946-55. Disponible en: <https://ieeexplore.ieee.org/abstract/document/4578740>
- [6]. GAWLAK A. "The influence of investment on reducing energy losses in distribution networks". In: 2015 16th International Scientific Conference on Electric Power Engineering (EPE); Kouty nad Desnou, Czech Republic; 2015, p. 315-319. DOI: 10.1109/EPE.2015.7161080. Disponible en: <https://ieeexplore.ieee.org/abstract/document/7161080>
- [7]. YIP S. C., *et al.* "Detection of Energy Theft and Metering Defects in Advanced Metering Infrastructure Using Analytics". In: 2018 International Conference on Smart Grid and Clean Energy Technologies (ICSGCE); Kajang; 2018, p. 15-22. DOI: 10.1109/ICSGCE.2018.8556710. Disponible en: <https://ieeexplore.ieee.org/document/8556710>
- [8]. ANEEL. Agência Nacional de Energia Elétrica. "Perdas de Energia Elétrica na Distribuição"; 2021. [Online]. [Accessed: 09-ago-2021]. Disponible en: <https://www.aneel.gov.br/documents/654800/18766993/Relat%C3%B3rio+Perdas+de+Energia+Edi%C3%A7%C3%A3o+12021.pdf/143904c4-3e1d-a4d6-c6f0-94af77bac02a>
- [9]. LEITE J. B. and Mantovani JRS. "Detecting and Locating Non-Technical Losses in Modern Distribution Networks". IEEE Transactions on Smart Grid. 2018; vol. 9, n. 2, :1023-1032. DOI: 10.1109/TSG.2016.2574714. Disponi8ble en: <https://ieeexplore.ieee.org/abstract/document/7482839>
- [10]. MADRIGAL M, Rico JJ and Uzcategui L. "Estimation of Non-Technical Energy Losses in Electrical Distribution Systems". IEEE Latin America Transactions. 2017; vol. 15, n. 8, p. 1447-52. DOI: 10.1109/TLA.2017.7994791. Disponible en: <https://ieeexplore.ieee.org/abstract/document/7994791>
- [11]. GLAUNER P., *et al.* "Large-scale detection of non-technical losses in imbalanced data sets". In: 2016 IEEE Power & Energy Society Innovative Smart Grid Technologies Conference (ISGT); Minneapolis, MN; 2016; p. 1-5. DOI:10.1109/ISGT.2016.7781159. Disponible en: <https://ieeexplore.ieee.org/abstract/document/7781159>

- [12]. QUINTERO Rojas G. A. and Gallego R. A. "Advanced analytics for non-technical losses of energy". In: 2015 IEEE PES Innovative Smart Grid Technologies Latin America (ISGT LATAM); Montevideo; 2015; p. 579-584. DOI: 10.1109/ISGT-LA.2015.7381219. Disponible en: <https://ieeexplore.ieee.org/document/7381219>
- [13]. NIZAR A. H., *et al.* "Load Profiling Method in Detecting non-Technical Loss Activities in a Power Utility". In: 2006 IEEE International Power and Energy Conference; Putra Jaya; 2006; p. 82-87. DOI: 10.1109/PECON.2006.346624. Disponible en: <https://ieeexplore.ieee.org/abstract/document/4154468>
- [14]. PENIN Carlos Alexandre. "Combate, Prevenção e Otimização de Perdas Comerciais de Energia Elétrica". Doctoral dissertation, Universidade de São Paulo; 2008. In Portuguese. Disponible en: https://www.google.com/url?sa=t&rct=j&q=&esrc=s&source=web&cd=&ved=2ahUKEwjI9Kj0gaLzAhVNTjABHcwOCZ8QFnoECAIOAQ&url=https%3A%2F%2Fwww.teses.usp.br%2Fteses%2Fdisponiveis%2F3%2F3143%2Ftd-14082008-092248%2Fpublico%2FDoctorPenin11.pdf&usg=AOvVaw1Ng1cx9xhccSs3J_SmVgza
- [15]. POVEDA M, "A new method to calculate power distribution losses in an environment of high unregistered loads". In: 1999 IEEE Transmission and Distribution Conference; 1999. Disponible en: <https://ieeexplore.ieee.org/document/756121>
- [16]. NAGI J, *et al.* "NTL detection of electricity theft and abnormalities for large power consumers In TNB Malaysia". In: 2010 IEEE Student Conference on Research and Development (Scored); Kuala Lumpur, Malaysia; 2010; p. 202-206. DOI:10.1109/SCORED.2010.5704002. Disponible en: <https://ieeexplore.ieee.org/document/5704002>
- [17]. ANEEL. Agência Nacional de Energia Elétrica. "Perdas de Energia"; 2015. [Online]. [Accessed: 30-Out-2020]. Disponible en: https://www.aneel.gov.br/metodologia-distribuicao/-/asset_publisher/e2INtBH4EC4e/content/perdas/654800?inheritRedirect=false
- [18]. ALVES R., *et al.* "Reduction of Non-Technical Losses by Modernization and Updating of Measurement Systems". In: 2006 IEEE/PES Transmission & Distribution Conference and Exposition: Latin America; Caracas; 2006; p. 1-5. DOI: 10.1109/TDCLA.2006.311590. Disponible en: <https://ieeexplore.ieee.org/abstract/document/4104521>
- [19]. ROMERO Agüero J. "Improving the efficiency of power distribution systems through technical and non-technical losses reduction". In: 2012 PES T&D; Orlando, FL; 2012; p. 1-8. DOI: 10.1109/TDC.2012.62816-52. Disponible en: <https://ieeexplore.ieee.org/document/6281652>
- [20]. PERALTA J, *et al.* "BC Hydro's methodology for energy losses assessment in distribution systems". In: 2009 IEEE Electrical Power & Energy Conference (EPEC); Montreal, QC; 2009; p. 1-6. DOI: 10.1109/EPEC.2009.5420813. Disponible en: <https://ieeexplore.ieee.org/abstract/document/5420813>
- [21]. SAHOO S, *et al.* "Electricity Theft Detection Using Smart Meter Data". In: 2015 IEEE PES Innovative Smart Conference of Technologies Grid (ISGT). Disponible en: <https://ieeexplore.ieee.org/abstract/document/7131776>
- [22]. CHANDEL P, Thakur T, Sawale BA. "Energy Meter tampering: Major cause of non-technical losses in Indian distribution sector". In: 2016 International Conference on Electrical Power and Energy Systems (ICEPES); Bhopal; 2016; p. 368-371. DOI: 10.1109/ICEPES.2016.7915959. Disponible en: <https://ieeexplore.ieee.org/document/7915959>
- [23]. BUZAU M, *et al.* "Hybrid Deep Neural Networks for Detection of Non-Technical Losses in Electricity Smart Meters". IEEE Transactions on Power Systems. 2020; vol. 35, n.2, p. 1254-1263. Disponible en: <https://ieeexplore.ieee.org/abstract/document/8846082>
- [24]. ARANHA Neto EAC and Coelho J, "Probabilistic methodology for Technical and Non-Technical Losses estimation in distribution system". Electrical Power Systems Res. 2013; vol. 97, n. 1, p. 93-99. Disponible en: <https://www.sciencedirect.com/science/article/abs/pii/S0378779612003604>
- [25]. CHEN PY and Popovich PM. "Correlation: parametric and nonparametric measures". London: Sage; 2002; p.95. ISBN-13: 978-0761922285. Disponible en: <https://www.amazon.com/-/es/Peter-Y-Chen/dp/0761922288>
- [26]. JUPP V. "The Sage Dictionary of Social Research Methods". London: Sage; 2006; vol. 7, n. 2, p.43. Disponible en: <https://go.gale.com/ps/i.do?id=GALE%7CA179076978&sid=googleScholar&v=2.1&it=r&linkaccess=abs&issn=14480980&p=AONE&sw=w&userGroupName=anon%7E15c9df4b>
- [27]. MOORE DS, and McCabe GP. "Introduction to the Practice of Statistics". New York: W.H. Freeman and Company; 2003; p.127. Disponible en: <https://www.amazon.com/-/es/David-S-Moore/dp/1319013384>
- [28]. PARANHOS R, *et al.* "Desvendando os Mistérios do Coeficiente de Correlação de Pearson: o Retorno". São Paulo: Leviathan; 2014; n. 8, p. 66-95. In Portuguese. Disponible en: <https://www.revistas.usp.br/leviathan/article/view/132346>
- [29]. COHEN J. "Statistical Power Analysis for the Behavioral Sciences". 2th ed. Mahwah, NJ: Lawrence Erlbaum Associates; 1989. vol. 84, n. 408, p. 1096. Disponible en: <https://go.gale.com/ps/i.do?id=GALE%7CA261631854&sid=googleScholar&v=2.1&it=r&linkaccess=abs&issn=01621459&p=AONE&sw=w&userGroupName=anon%7Eee2dc1be>

- [30]. DANCEY CP, and Reidy J. ``Estatística Sem Matemática para Psicologia: Usando SPSS para Windows``. Porto Alegre: Artmed; 2006. In Portuguese. Disponible en: <https://pesquisa.bvsalud.org/portal/resource/pt/biblio-939171>
- [31]. MUKAKA M. M. "A guide to appropriate use of correlation coefficient in medical research". Malawi Medical Journal; 2012; vol. 24, n. 3, p. 69-71. PMID: 23638278; PMCID: PMC3576830. Disponible en: <https://www.ajol.info/index.php/mmj/article/view/81576>
- [32]. FISCHER H. ``A History of the Central Limit Theorem``. Springer Science& Business Media; 2011. ISBN 978-0-387-87856-0. Disponible en: <https://link.springer.com/book/10.1007/978-0-387-87857-7>
- [33]. CONOVER W. J. ``Practical nonparametric statistics``. vol. 350 .USA: John Wiley & Sons; 1998. Disponible en: https://books.google.com/cu/books?hl=es&lr=&id=n_39DwAAQBAJ&oi=fnd&pg=PA1&dq=Practical+nonparametric+statistics&ots=L9ctZJkIKa&sig=KfhRHKuWdhZYjTv6zuVAA_eaW8M&redir_esc=y#v=onepage&q=Practical%20nonparametric%20statistics&f=false

CONFLICT OF INTERESTS

The authors declare that there are no conflicts of interest.

AUTHOR'S CONTRIBUTION

Vinicius de Oliveira: <https://orcid.org/0000-0001-8314-5907>

Elaboration of the research, validation of the manuscript, conceptualization, methodology, draft, editing and review of the manuscript, as well in the approval drafting and of the final report.

Duan Vilela Ferreira: <https://orcid.org/0000-0002-5907-1124>

Elaboration of the research, conceptualization, methodology, critical review of its content, as well as in the drafting and approval of the final report.

Tarso Vilela Ferreira: <https://orcid.org/0000-0002-3852-8586>

Critical review of its content, as well as in the drafting and approval of the final report.