



Revista Politécnica

ISSN: 1390-0129

ISSN: 2477-8990

Escuela Politécnica Nacional

Sebastián, Sarasti-Zambonino; Tania, Barahona; Santos, Roque
Simulation of a HPGe Detector with GEANT4
Revista Politécnica, vol. 50, no. 2, 2023, November-January, pp. 7-14
Escuela Politécnica Nacional

DOI: <https://doi.org/10.33333/rp.vol50n2.01>

Available in: <https://www.redalyc.org/articulo.oa?id=688774232001>

- How to cite
- Complete issue
- More information about this article
- Journal's webpage in redalyc.org

UNEM  redalyc.org

Scientific Information System Redalyc
Network of Scientific Journals from Latin America and the Caribbean, Spain and
Portugal

Project academic non-profit, developed under the open access initiative

Simulation of a HPGe Detector with GEANT4

Sarasti-Zambonino, Sebastián^{1,*} ; Barahona, Tania² ; Roque, Santos¹ 

¹Escuela Politécnica Nacional, Departamento de Ciencias Nucleares, Quito, Ecuador

²Escuela Politécnica Nacional, Departamento de Ingeniería Química, Quito, Ecuador

Abstract: Gamma spectroscopy is an analytic technique that identifies isotopes through gamma rays. Currently, gamma spectroscopy is widely used in several science fields, for instance, the study of the hydrodynamics of soils and other applications. Considering the development of computers, it has been developed Monte-Carlo simulation packages, in order to estimate the response of gamma spectroscopy detectors. This work aims to develop a GEANT4 application to estimate the full energy peak efficiency for a HPGe detector and determine the deviation with experimental data. It was carried out measurements of the next radioactive sources, Am-241, Eu-152, Cs-137, and Co-60. These measurements were made at different distances, they were at 0, 5, 10, 20, and 25 cm from the detector's cover layer. Meanwhile, the simulation was carried out through user action classes to extract energy deposited in the sensitive detector. It was determined full energy peak efficiency of experimental data, through these results, it was estimated a detection factor that measures the deviation between experimental and simulated data. A reason for the deviation was that the simulation did not include the electronic chain of acquisition. Finally, it was suggested that future works should develop a more accurate simulation for multi-emitters isotopes.

Keywords: Gamma spectroscopy, Instrumental analyses, Monte-Carlo simulations, radiation transport

Simulación de un Detector de HPGe con GEANT4

Resumen: La espectroscopía gamma es una técnica analítica que identifica los isótopos mediante las emisiones de rayos gamma de cada uno de estos. En la actualidad, esta técnica tiene gran relevancia debido a un amplio espectro de aplicaciones como el estudio de la hidrodinámica del suelo y otras aplicaciones. Con el desarrollo de la computación moderna, se han desarrollado softwares de simulación Monte-Carlo que permiten estimar la respuesta de los detectores empleados en la espectroscopía gamma. El objetivo de este trabajo es desarrollar una aplicación en GEANT4 para estimar la eficiencia máxima de energía total para un detector de HPGe y determinar la desviación de los datos experimentales. Para lo cual, se realizó mediciones de Am-241, Eu-152, Cs-137, y Co-60 a las distancias de 0, 5, 10, 20 y 25 cm desde el recubrimiento superior del detector, cada uno respectivamente. La simulación se desarrolló mediante acciones de usuario para extraer la energía depositada en el volumen sensible. A partir de esto, se determinó la eficiencia máxima de energía total de los datos experimentales, luego se determinó un factor de detección que estimaba la desviación del resultado simulado con experimental. Se planteó que una razón de este comportamiento es la ausencia de la simulación de la cadena electrónica. Finalmente, se sugiere que futuros trabajos desarrollen simulaciones más precisas para isótopos multiemisores.

Palabras clave: Espectroscopía gamma, análisis instrumental, Monte-Carlo simulaciones, transporte de radiación

1. INTRODUCTION

Gamma spectroscopy is an analytic technique that identifies isotopes through the gamma photons emitted by each radionuclide. This technique employs two types of radiation detectors: scintillators and semiconductors. One of the most employed semiconductor materials for radiation measurements is Hyper-Pure Germanium (HPGe) detector. This detector has a cylinder crystal inside in a vacuum-tight cryostat of HPGe (Turner, 2007). In the market, it is possible to find detectors with different configurations such as planar or coaxial. The size of the detector generally changes among

the manufacturers and the aims of the studies (Demir et al., 2013; Marzocchi et al., 2010).

Additionally, the main difference between scintillation and semiconductor detector is the resolution, which is the capability of generating a well-defined peak based on the radiation emitted by an isotope. A way to measure the resolution in spectra is the peak full width at one-half of the maximum (FWHM), when FWHM is low it means high resolution in spectra. In this sense, semiconductor detectors are characterized by having a higher resolution than scintillators. In fact, a scintillation detector, the FWHM of NaI (Tl) detector

*sebitas.alejo@hotmail.com

Recibido: 13/01/2022

Aceptado: 21/06/2022

Publicado en línea: 04/08/2022

10.33333/rp.vol50n2.01

CC 4.0

is around 30-50 times greater than FWHM of HPGe detector (Perez-Andujar & Pibida, 2004). This feature of allow the discrimination between nearby peaks in the spectra. For this reason, semiconductor detectors have been used to identify samples with multi-emitter isotopes (Siegel, 2013). Identification of isotopes is not the only application of gamma spectroscopy; this technique is also used in several science fields. For instance, gamma spectroscopy is used to study and understand the hydrodynamics of the soils. These types of studies are conducted for the optimization of water resources (Baldoncini et al., 2019; Strati et al., 2018). Furthermore, gamma spectroscopy is employed to study the composition of planets and stars far beyond earth (Sanin et al., 2020). A more conventional application is the characterization of isotopes for neutron calibration sources, such as Cf-252, or to analyze radionuclide distribution in soils (Ahmed, 2020; Watson et al., 2021).

Gamma radiation emitted by radioactive isotopes enters the semiconductor detector and promotes electrons for the valence band to the conduction band. The number of electrons promoted is proportional to the energy of the radiation emitted. An electric field is applied to the semiconductor, so the electrons can be driven to the positive terminal and be counted. Each interaction generates one count, and it is called an impulse; it is possible to classify each impulse based on its height. Energy calibration is the procedure by which the intensity (or height) of the impulse is related to the energy of the radiation emitted (Del Sordo et al., 2009).

Not all the energy released by an atom reaches the detector, most of the radiation is lost since it is not inside the solid angle between the detector and the source. Efficiency calibration is the procedure that allows the estimation of the radiation lost because of this characteristic. In order to quantify the amount of an isotope present in a sample, both calibrations (energy and efficiency) must be performed for a specific detector (Abbas, 2010; Abbas et al., 2006; Martin & Burns, 1992).

Gamma spectroscopy calibrations are traditionally made with standard samples of a known activity and defined volume. This process is made to measure what fraction of radiation, of the total emitted by the isotope, is registered by the detector. This calibration is known as full energy peak efficiency (FEPE) calculations (Elekes et al., 2003). Nevertheless, this process is costly due to standards acquisition, and it can be challenging to find standards of irregular volumes. This problem can be solved with Monte-Carlo simulations (Vidmar, 2005). Monte-Carlo simulations are a way to solve radiation transport equations. The first application of a Monte-Carlo method was proposed by von Neumann in the Manhattan project (Benov, 2016) in order to calculate the critical mass of the atomic bomb. There are several software packages to perform Monte-Carlo simulations. Among the most important codes it can be mentioned: MCNP, TRIPOLI, FLUKA, and GEANT4 (Agostinelli et al., 2003; Battistoni et al., 2007; Kirk, 2010). It is worth mentioning that GEANT4 is an open code, free to download and use. GEANT4 code allows users to simulate a wide spectrum of particles. Regarding applications of GEANT4, it is used to perform FEPE calculations, estimate response of detectors facing sources at different geometries, or

calculation of self-absorption correction factors (Guembou et al., 2018; Hurtado et al., 2004, 2007).

The objective of this work is to develop a GEANT4 application to estimate the full energy peak efficiency for a HPGe detector and their deviations of experimental measurements. This work aims to be a seed for future works which will develop more accurate applications, especially for irregular volumes.

2. MATERIALS AND METHODS

2.1 Experimental measurements

Gamma spectroscopy measurements were carried out with a Canberra Hyper Pure Germanium (HPGe) detector model BE2020 and a cryostat 2002CSL with serial 8639. The detector was plugged into a multichannel analyzer model LYNX to save information in 8190 channels. The radioactive sources employed were: Am-241, Eu-152, Cs-137, and Co-60. These sources were placed at 0, 5, 10, 20, and 25 cm from the top of the cover of the detector in a straight line.

Registered results were analyzed in Python. A channel calibration was done to adjust all spectra in terms of energies. To perform such calibration, an isotope with well-known emission energy was used as a reference, and the channel at which the radiation was detected, was equated to the energy emitted. This allows for the transformation from a peak detected at a specific channel to a peak detected at a defined energy. The energies used for regression are detailed in Table 1, and they were obtained from similar works (Duc Tam et al., 2017).

Additionally, it was made a FEPE calibration of the HPGe detector. This process was made for each photo-peak detailed in Table 1. Equation 1 was used to calculate the FEPE. Efficiency calibrations were made to each data set of spectra at different distances.

$$FEPE = \frac{C_p}{A_c * P} \quad (1)$$

Where:

FEPE: full energy peak efficiency

C_p : area under in the photopeak

A_c : activity of the sample

P : energies' probability of emission

Table 1. Data of radioactive sources used

Source	Emission Energy (keV)	Probability of emission (%)	Measured Activity (Bq)
Am-241	59.54	35.92	37210.71
	121.78	28.41	
	244.7	7.55	
Eu-152	344.28	26.59	8291.76
	661.66	84.99	
	1173.23	99.88	
Cs-137	1332.49	100.00	20030.49

2.2 Simulation

The simulation was performed in GEANT4. Three basic classes were defined: detector construction, physics list, and primary generator. To extract useful information from the simulation, the following user action classes were also instantiated: Run Action, Event Action, and Stepping Action classes.

Through the detector construction class, the geometry shown in Figure 1 was implemented in the simulation. The following modular physics list were used for performing the simulation of the physical process: G4RadioactiveDecay, G4DecayPhysics, and G4EmStandardPhysics. For implementing the radioactive source through a primary generator class, it was employed General Particle Source because it facilitates the generation of particles with macro commands. The simulations' geometries were the same as experimental measurements. A radioactive source was placed at 0, 5, 10, 20, and 25 cm from the top of the cover of the detector. However, it is important to point out that several isotropic gamma sources for Am-241, Eu-152, and Cs-137 were simulated to emulate the multipeak generation of such isotopes. Am-241 was simulated through a 59.54 keV gamma isotropic source. Eu-152 was simulated through three different isotropic gamma sources of 121.78 keV 244.7 keV, and 344.28 keV. Cs-137 was simulated with a 662 keV gamma isotropic source. This was done because simulating all radioactive decay processes uses a lot of computation time. Only for Co-60, the whole radioactive decay process was simulated because it did not take a large amount of time.




Figure 1. The geometry of the HPGe detector simulated

User action classes were programmed to save energy deposited in each step. Energy deposition was done with Stepping Action class. Summing up all the energy deposition around an event was done in Event Action class. The events with zero energy deposition were ignored. Run action class was made to plot a ntuple with energy deposition and its counts.

The simulated spectra were scaled up to the activity of each radioactive source used in each experimental setup. This

process was done because the Monte-Carlo simulation just estimate the response of the detector for a known number of particles, but there is no time relation whatsoever. Therefore, it was calculated how much time the real radioactive source would take to emit the same number of particles as the Monte-Carlo simulation. This process was done by dividing each spectrum bin to the activity correction factor. Activity correction is basically a pseudo time of measurement, and it was estimated through equation 2.

$$f_a = \frac{N_p}{A_c * P} \quad (2)$$

Where:

f_a : activity correction factor (s)

N_p : number of the simulated particles

A_c : activity of the sample (Bq)

P : the probability of emission

Simulated spectra with activity correction factor were transformed into simulated net count rate spectra. These rates were compared with the experimental net count rate spectra. Then, another correction factor was estimated, this was calculated through Equation 3. This correction factor was called the detection factor (f_c), and it measures how much the simulation diverts from experimental results. This process was carried out at the photo-peaks detailed in Table 1, for each set of spectra data for all distances. Scaling was performed by dividing each net count rate spectrum interval by the value in each energy of f_c .

$$f_c = \frac{M_s}{M_e} \quad (3)$$

Where:

M_s : maximum value of the photo-peak in simulated net count rate spectrum

M_e : maximum value of the photo-peak in experimental net count rate spectrum

Finally, the error was estimated between simulated net count rate spectra with detection correction factor and net count rate spectra. This process was done with Equation 4.

$$Error (\%) = \frac{N_s - N_e}{N_e} * 100 \quad (4)$$

Where:

N_s : number of counts in the maximum value of the photo-peak in simulated net count rate spectrum

N_e : number of counts in the maximum value of the photo-peak in experimental net count rate spectrum

3. RESULTS

The energy calibration curve is shown in Figure 2. In this curve, the relation between energy and detection channel is established. The curve has a correlation factor (R^2) of 0.99. It means that the model used in linear regression has a good fitting with experimental results (Shtatland et al., 2002).




Figure 2. Energy calibration of HPGe detector

Figure 3 shows FEPE for different energies at different distances. The FEPE curves are lower when distance increases, this is caused by variation of the solid angle as the source is placed farther from the detector. This behavior of radiation detector had been studied by previous researchers (Krneta Nikolić et al., 2018; Smith & Kearfott, 2018).




Figure 3. Full energy peak efficiency calibration of HPGe detector at different distances

Curves of Figure 3 were compared with similar data obtained by third-party experiments. We compare our measurements with those obtained by Ješkovský et al. (2019), Khan et al. (2018), and Aviv & Elia (2020). These results vary among them because HPGe crystals present different features that depend upon the manufacturer, the thick of the dead layer, and the crystal state. On one hand, the detectors employed by Ješkovský et al. (2019), and Khan et al. (2018), tend to have a behavior that increases the FEPE until a zone near to 100 keV. After this range of energy in those type of detectors, the FEPE curve tends to decrease with energy (Ješkovský et al., 2019; Khan et al., 2018). On the other hand, the detectors employed by Aviv & Elia (2020) the FEPE decreases while energy increases (Aviv & Elia, 2020). Analysis of figure 3 shows our values are different from Ješkovský et al. (2019), and Khan et al. (2018) but have similarities with Aviv & Elia. In fact, a plausible reason for that behavior is in the first works p-type HPGe detectors were used. These devices are cylinders with empty concentric cavities. Even though p-type HPGe crystal

are chemically the same, they have a different geometry from the BE2020, the detector employed in our work. Conversely, the work made by Aviv & Elia (2020) employed the broad energy detector, like we do. This detector is a fully filled cylinder. However, in contrast with our equipment, Aviv & Elia's (2020) is bigger (8 cm), so the capability for detecting radiation is higher than ours.

Figure 4 shows the comparison among spectra. The blue solid line represents the simulated spectrum without any correction. The green dotted line is the simulated curve corrected with the activity factor, and the red dotted line is the experimental result. The spectrum without detection factor is several times greater than the experimental spectrum. One reason for this anomaly is that GEANT4 does not simulate the electronic chain of acquisition. It is also important to note the difference in how a spectrum is recorded in the simulation in comparison to the experimental result. Simulated spectra have a greater photopeak because for GEANT4 is enough for a particle to arrive at the detector and deposit its energy in order to consider it as an impulse. However, in experimental measurements, it is needed for a particle to arrive at the HPGe detector, which deposits enough energy for promoting an electron to a conduction band, and only then to count it as an impulse.




Figure 4. Comparison between spectra for 662 keV gamma photo-peak at 5 cm

The variation of the detection factor with energy and distance was also studied. The correction factor value was averaged for the same energy value for different experimentation distances, to eliminate the influence of distance. After that, the mean detection factor for each energy was plotted and is shown in Figure 5. This mean detection factor was used to scale the simulated spectra with activity correction. When comparing the tendency between Figure 3 and Figure 5, it can be inferred that the correction factor is inversely proportional to full energy peak efficiency calibration. The minimum overestimation of GEANT4's simulation is four times, and the greater overestimation is eleven times approximately.




Figure 5. Correction factor and different energies

Finally, it was measured the error between rescaled spectra with activity correction and detection correction. The errors are presented in Table 2.

Table 2. Error at each energy and distance

Energy	Distance				
	0 cm	5 cm	10 cm	20 cm	25 cm
Am-241 59.5 keV	20.81	21.77	2.20	42.25	2.53
Eu-152 121 keV	57.37	3.98	15.29	18.29	19.80
Eu-152 244 keV	83.81	11.83	20.60	25.23	26.13
Eu-152 344 keV	31.95	1.44	8.72	9.85	14.82
Cs-137 662 keV	17.51	1.13	4.70	7.65	6.28
Co-60 1173 keV	5.67	3.38	7.54	2.38	7.64
Co-60 1332 keV	15.77	3.82	4.49	13.98	20.08

It is important to mention that errors are higher for Eu-152 simulations. The reason for this difference could be that for the Eu-152 was simulated each photo-peak alone, but in real life, Eu-152 emits all these energies at once. Therefore, the detector saturates more easily for sources in the real experiment, especially when the isotope emits several different energies. Next simulations should be focused on multi-emitters radionuclides with all radioactive decay processes occurring simultaneously.

All files employed for data analyses are available in this repository https://github.com/sebassaras02/HPGe_data_rp_publication.git. Meanwhile, the GEANT4 application is available in this repository: https://github.com/sebassaras02/HPGe_G4_rp_publication.git.

4. CONCLUSIONS

The present work developed a GEANT4 simulation to estimate the response of the HPGe detector for gamma spectroscopy. Am-241, Eu-152, Cs-137, and Co-60 sources were simulated. Furthermore, it was scaling the spectra to activity measured, and then it was determined a detection factor, in order to estimate how much simulation diverts from experimental measurements. In addition to this work, our data was compared with third-party experiments, and it shows similar detector behavior. Finally, it was pointed out that errors are higher for Eu-152 simulations. The reason for this difference could be that for the Eu-152 was simulated each photo-peak alone, but in real life, Eu-152 emits all these energies at once.

New simulations must improve the simulation for multi-emitter radioactive sources.

REFERENCES

- Abbas, M. I. (2010). Analytical formulae for borehole scintillation detectors efficiency calibration. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 622(1), 171–175. <https://doi.org/10.1016/J.NIMA.2010.06.241>
- Abbas, M. I., Nafee, S., & Selim, Y. S. (2006). Calibration of cylindrical detectors using a simplified theoretical approach. *Applied Radiation and Isotopes*, 64(9), 1057–1064. <https://doi.org/10.1016/J.APRADISO.2006.05.005>
- Agostinelli, S., Allison, J., Amako, K., Apostolakis, J., Araujo, H., Arce, P., Asai, M., Axen, D., Banerjee, S., Barrand, G., Behner, F., Bellagamba, L., Boudreau, J., Broglia, L., Brunengo, A., Burkhardt, H., Chauvie, S., Chuma, J., Chytrcek, R., ... Zschesche, D. (2003). Geant4—a simulation toolkit. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 506(3), 250–303. [https://doi.org/https://doi.org/10.1016/S0168-9002\(03\)01368-8](https://doi.org/https://doi.org/10.1016/S0168-9002(03)01368-8)
- Ahmed, R. S. (2020). A review on soil radionuclide distribution in Iraq analysed using gamma ray spectroscopy. *Environmental Forensics*, 22(1–2), 91–98. <https://doi.org/10.1080/15275922.2020.1805827>
- Aviv, O., & Elia, P. (2020). Monte-Carlo simulations of the full-energy-peak efficiency for a broad-energy germanium detector—a comparison between GEANT4 and FLUKA. *Journal of Instrumentation*, 15(05), P05016. <https://doi.org/10.1088/1748-0221/15/05/P05016>
- Baldoncini, M., Albéri, M., Bottardi, C., Chiarelli, E., Raptis, K. G. C., Strati, V., & Mantovani, F. (2019). Biomass water content effect on soil moisture assessment via proximal gamma-ray spectroscopy. *Geoderma*, 335, 69–77. <https://doi.org/10.1016/J.GEODERMA.2018.08.012>
- Battistoni, G., Cerutti, F., Fassò, A., Ferrari, A., Muraro, S., Ranft, J., Roesler, S., & Sala, P. R. (2007). The FLUKA code: description and benchmarking. *AIP Conference Proceedings*, 896(1), 31. <https://doi.org/10.1063/1.2720455>
- Benov, D. M. (2016). The Manhattan Project, the first electronic computer and the Monte Carlo method. *Monte Carlo Methods and Applications*, 22(1), 73–79. <https://doi.org/10.1515/mcma-2016-0102>
- Del Sordo, S., Abbene, L., Caroli, E., Mancini, A. M., Zappettini, A., & Ubertini, P. (2009). Progress in the Development of CdTe and CdZnTe Semiconductor Radiation Detectors for Astrophysical and Medical Applications. *Sensors 2009, Vol. 9, Pages 3491–3526*, 9(5), 3491–3526. <https://doi.org/10.3390/S90503491>
- Demir, D., Eroğlu, M., & Turşucu, A. (2013). Studying of characteristics of the HPGe detector for radioactivity measurements. *Journal of Instrumentation*, 8(10). <https://doi.org/10.1088/1748-0221/8/10/P10027>

- Duc Tam, H., Hai Yen, N. T., Tran, L. B., Dinh Chuong, H., & Thien Thanh, T. (2017). Optimization of the Monte Carlo simulation model of NaI(Tl) detector by Geant4 code. *Applied Radiation and Isotopes*, 130, 75–79. <https://doi.org/10.1016/j.apradiso.2017.09.020>
- Elekes, Z., Belgya, T., Molnár, G. L., Kiss, Á. Z., Csatlós, M., Gulyás, J., Krasznahorkay, A., & Máté, Z. (2003). Absolute full-energy peak efficiency calibration of a Clover-BGO detector system. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 503(3), 580–588. [https://doi.org/10.1016/S0168-9002\(03\)00998-7](https://doi.org/10.1016/S0168-9002(03)00998-7)
- Guembou Shouop, C. J., Ndontchueng Moyo, M., Nguemle Mekongtso, E. J., Motapon, O., & Strivay, D. (2018). Monte Carlo method for gamma spectrometry based on GEANT4 toolkit: Efficiency calibration of BE6530 detector. *Journal of Environmental Radioactivity*, 189, 109–119. <https://doi.org/10.1016/J.JENVRAD.2018.03.015>
- Hurtado, S., García-León, M., & García-Tenorio, R. (2004). Monte Carlo simulation of the response of a germanium detector for low-level spectrometry measurements using GEANT4. *Applied Radiation and Isotopes*, 61(2–3), 139–143. <https://doi.org/10.1016/J.APRADISO.2004.03.035>
- Hurtado, S., Villa, M., Manjón, G., & García-Tenorio, R. (2007). A self-sufficient and general method for self-absorption correction in gamma-ray spectrometry using GEANT4. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 580(1), 234–237. <https://doi.org/10.1016/J.NIMA.2007.05.090>
- Jeřkovský, M., Javorník, A., Breier, R., Slučiak, J., & Povinec, P. P. (2019). Experimental and Monte Carlo determination of HPGe detector efficiency. *Journal of Radioanalytical and Nuclear Chemistry* 2019 322:3, 322(3), 1863–1869. <https://doi.org/10.1007/S10967-019-06856-4>
- Khan, W., Zhang, Q., He, C., & Saleh, M. (2018). Monte Carlo simulation of the full energy peak efficiency of an HPGe detector. *Applied Radiation and Isotopes*, 131, 67–70. <https://doi.org/10.1016/J.APRADISO.2017.11.018>
- Kirk, B. L. (2010). Overview of Monte Carlo radiation transport codes. *Radiation Measurements*, 45(10), 1318–1322. <https://doi.org/10.1016/J.RADMEAS.2010.05.037>
- Krneta Nikolić, J., Rajačić, M., Todorović, D., Janković, M., Sarap, N., Pantelić, G., & Vukanac, I. (2018). Semiempirical efficiency calibration in semiconductor HPGe gamma-ray spectroscopy. *Journal of Spectroscopy*, 2018. <https://doi.org/10.1155/2018/5392658>
- Martin, L. J., & Burns, P. A. (1992). The HPGe as a defined-solid-angle detector for low-energy photons. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 312(1–2), 146–151. [https://doi.org/10.1016/0168-9002\(92\)90145-T](https://doi.org/10.1016/0168-9002(92)90145-T)
- Marzocchi, O., Breustedt, B., & Urban, M. (2010). Characterisation, modelling and optimisation of the model of a HPGe detector with the aid of point sources. *Applied Radiation and Isotopes*, 68(7–8), 1438–1440. <https://doi.org/10.1016/J.APRADISO.2009.11.022>
- Perez-Andujar, A., & Pibida, L. (2004). Performance of CdTe, HPGe and NaI(Tl) detectors for radioactivity measurements. *Applied Radiation and Isotopes*, 60(1), 41–47. <https://doi.org/10.1016/J.APRADISO.2003.10.006>
- Sanin, A. B., Mitrofanov, I. G., Bakhtin, B. N., Litvak, M. L., Anikin, A. A., Golovin, D. v., & Nikiforov, S. Y. (2020). On the Study of the Spatial Variability of the Composition of the Lunar Material in Experiments on Gamma Spectroscopy Onboard a Mobile Spacecraft Using the Tagged-Cosmic-Rays Method. *Solar System Research* 2020 54:6, 54(6), 477–487. <https://doi.org/10.1134/S0038094620060052>
- Shtatland, E. S., Kleinman, K., & Cain, E. M. (2002). One more time about R2 measures of fit in logistic regression. *NESUG 15 Proceedings*, 15, 222–226. <https://citeseerx.ist.psu.edu/viewdoc/download?doi=10.1.1.503.5183&rep=rep1&type=pdf>
- Siegel, P. B. (2013). Gamma spectroscopy of environmental samples. *American Journal of Physics*, 81(5), 381. <https://doi.org/10.1119/1.4793595>
- Smith, T., & Kearfott, K. J. (2018). Practical Considerations for Gamma Ray Spectroscopy with NaI(Tl): A Tutorial. *Health Physics*, 114(1), 94–106. <https://doi.org/10.1097/HP.0000000000000804>
- Strati, V., Albéri, M., Anconelli, S., Baldoncini, M., Bittelli, M., Bottardi, C., Chiarelli, E., Fabbri, B., Guidi, V., Raptis, K. G. C., Solimando, D., Tomei, F., Villani, G., & Mantovani, F. (2018). Modelling Soil Water Content in a Tomato Field: Proximal Gamma Ray Spectroscopy and Soil-Crop System Models. *Agriculture* 2018, Vol. 8, Page 60, 8(4), 60. <https://doi.org/10.3390/AGRICULTURE8040060>
- Turner, J. (2007). *Atoms, Radiation, and Radiation Protection* (3th ed.). WILEY-VCH Verlag GmbH & Co. https://books.google.com.ec/books?hl=es&lr=&id=-NjMPZEt2yUC&oi=fnd&pg=PR7&dq=atoms,+radiation+and+radiation+protection&ots=A-3xICU4-V&sig=acNQdybqp07hoDmVDj6zO0_4mwc&redir_esc=y#v=onepage&q=atoms%20%20radiation%20and%20radiation%20protection&f=false
- Vidmar, T. (2005). EFFTRAN—A Monte Carlo efficiency transfer code for gamma-ray spectrometry. *Nuclear Instruments and Methods in Physics Research Section A: Accelerators, Spectrometers, Detectors and Associated Equipment*, 550(3), 603–608. <https://doi.org/10.1016/J.NIMA.2005.05.055>
- Watson, M. M., Venkataraman, R., & Croft, S. (2021). Characterization of 252Cf sources using high-resolution gamma spectroscopy. *Applied Radiation and Isotopes*, 169, 109531. <https://doi.org/10.1016/J.APRADISO.2020.109531>

BIOGRAPHIES



Sebastián Sarasti Zambonino, he was born in Latacunga, but he grew up in Pujili. Currently, he studied a bachelor's degree in Chemical Engineering at Escuela Politecnica Nacional. He worked at the Nuclear Science Department at Escuela Politecnica Nacional as undergraduate research assistant. He has expertise on

gamma spectroscopy with scintillation and semiconductor detectors. Furthermore, his research is focused on radiation transport simulations with GEANT4. He is able to use the next programming languages: Python, Matlab and C++.



Tania Barahora, she was born in Sangolqui in 1994. She got her bachelor's degree from Escuela Politécnica Nacional in May 2021. She made a final project in Nuclear Science Department called "Desarrollo de un modelo digital para la simulación de un detector de Germanio Hiperpuro (HPGe) frente a fuentes de diferente

geometría". Through this work, she got experience on gamma spectroscopy with semiconductors and radiation transport simulation with Monte Carlo N-Particle.



Roque Santos, he was born in Quito in 1983. He got a bachelor's degree in Chemical Engineering from Escuela Politécnica Nacional in 2009. In 2010, he got a master's degree in Nuclear Engineering and Application from Universidad Autónoma de Madrid. He started to be an associate professor in Nuclear Science

Department at Escuela Politécnica Nacional in 2010. In 2017, he got his Ph.D. in Nuclear Engineering from University of Tennessee at Knoxville. Professor Santos research is focused on radiation detection applied to chemical engineering.

