



Journal of Applied Research and Technology

ISSN: 1665-6423

jart@aleph.cinstrum.unam.mx

Centro de Ciencias Aplicadas y Desarrollo

Tecnológico

México

Din, I.; Kim, J.; Kim, H.

Joint Power and Beam Angle Control for Energy Efficiency in Lighting Control Systems

Journal of Applied Research and Technology, vol. 11, núm. 3, junio, 2013, pp. 402-407

Centro de Ciencias Aplicadas y Desarrollo Tecnológico

Distrito Federal, México

Available in: <http://www.redalyc.org/articulo.oa?id=47427855010>

- How to cite
- Complete issue
- More information about this article
- Journal's homepage in redalyc.org

redalyc.org

Scientific Information System

Network of Scientific Journals from Latin America, the Caribbean, Spain and Portugal

Non-profit academic project, developed under the open access initiative

# Joint Power and Beam Angle Control for Energy Efficiency in Lighting Control Systems

I. Din<sup>1</sup>, J. Kim<sup>2</sup>, H. Kim<sup>\*1</sup>

<sup>1</sup> Department of Electronics Engineering, University of Incheon,  
Incheon, South Korea.

\*hoon@incheon.ac.kr

<sup>2</sup> Ministry of Knowledge Economy,  
Seoul, South Korea.

## ABSTRACT

This paper considers an energy-efficient utilization in lighting control systems (LCS). A joint power and beam angle control in LCS is proposed that reduces energy consumption while satisfying the user's lighting requirements. A problem to find the optimal pair of power and the beam angle of luminaries is formulated and an algorithm to find the optimal solution is suggested. The simulation results show that the proposed scheme achieves considerable improvement in energy savings compared to conventional lighting energy saving scheme which does not consider the beam angle control.

Keywords: beam angle control, energy efficiency, lighting control system, optimization.

## 1. Introduction

Energy efficiency has recently been receiving more and more attention for solving energy problems such as climate change and depletion of fossil fuels. It is said that almost a fifth of the total generated electricity is consumed for lighting and about 40% of total energy consumption for lighting is taken by office buildings [1, 2]. Therefore, lighting energy savings in buildings is recognized as an important issue for reduction of energy consumption.

A promising approach for saving lighting energy in buildings is LCS. LCSs are intelligent systems for efficient control of lighting composed of electrical devices such as motion/photo sensors and lighting controllers. An LCS is generally conjunctive with communication networks, where communication between devices is performed using machine-to-machine communication in a wired or wireless manner [3, 5]. IEEE 1451, IBECS (integrated building environmental communication system) and DALI (digital addressable lighting interface), are some of the standard protocols for communication between devices in LCS [6]. Wireless technologies have been considered a promising approach for LCS, which has the advantage of ease of installation and retrofitting. Researchers have attempted to replace the traditional ceiling-mounted photosensors with

wireless sensors network, which results in similar or even high energy saving than traditional systems [7, 8]. By monitoring current light illuminance and user occupancy, an LCS controls lighting devices to provide sufficient lighting quality for indoor users, and energy-efficient lighting control algorithms for LCS have been receiving more attention, being regarded as a key technology for saving energy.

Recently there have been some works on lighting control algorithms in LCS to improve the energy efficiency of LCS while satisfying lighting requirements of the users. Meng-Shiuan et al. presented an LCS based on wireless sensor networks considering user activities and profiles, this scheme considers two kind of light devices, namely, whole lighting and local lighting devices, and two kind of sensors, namely fixed and portable sensors [9, 10]. Carrying portable sensors is not convenient in practical applications, also specifying current activities via portable sensors and controlling local lighting devices that can be controlled by the user locally increase the complexity of the proposed system. Ono et al. presented a lighting power control algorithm that provides the user-required illuminance levels while minimizing power consumption of the luminaires

[11]. Hiroyasu et al. optimized the illuminance distribution control using steepest-descent technique to minimize the difference between current illuminance and required illuminance level [12]. A lighting power optimization algorithm has also been proposed based on a linear programming (LP) problem that minimizes the total power of the luminaires while satisfying the user's requirements [13].

Lighting control algorithms in previous works can be effective in saving power by properly controlling illuminance or the power consumed by luminaires. However, a more efficient lighting control scheme can be developed if additional control parameters are considered. Considering that the beam angle of a luminaire can be adjusted by moving the reflector [14], this paper proposes joint power and beam angle control for enhanced lighting energy efficiency of an LCS. An optimization problem is formulated to minimize the total luminous flux of luminaires, and an algorithm to solve the optimization problem is suggested. The performance evaluation results show that the proposed scheme achieves improvement in power savings.

The rest of the paper is organized as follows. Section 2 introduces the system model. Section 3 presents the formulation of the optimization problem and the proposed algorithm for computing optimal power and beam angle. Section 4 presents the performance evaluation results of the proposed scheme. Finally, Section 5 concludes this paper.

## 2. System model

This paper considers an LCS in a room as shown in Figure 1. It is assumed that  $L$  identical luminaires are equally spaced on the ceiling of a room, while the floor is geographically divided into  $J$  identical squares grids (or "work places"). A zoning strategy is used to group grids into different zones base on identical illuminance requirements. Figure 2 shows a zoning strategy for a typical share office. The squares of the floor are grouped into three zones. Zone A consists of the grids where high illuminance is required for activities like reading or working on the computer, where zone B consists of grids at the center area of the office where the illuminance requirements is usually low, and zone C consists of grids located near the door of the office. A central control unit




Figure 1. Illuminance Model for an Indoor Room Environment With Lighting Control System.

(CCU) communicates with a luminaire controller (LC) and sensors using wireless network. The CCU gathers environmental information such as current illuminance level, occupancy data, and the required illuminance level from sensors or a user input device. Users are considered to have different illumination requirements according to their activities. The proper values for power and beam width of each luminaire are computed based on the information. The selected power and beam width information are sent to the LC, and the LC controls the power and beam width of each luminaire based on the information [15]. It is assumed that the information is collected and exchanged between different devices without any error and delay.

The energy ( $w$ ) spent in illuminating the room can be computed as

$$w = \sum_{i=1}^L P_i t_i \quad (1)$$

where  $P_i$  and  $t_i$  are the input power and operating time (hour) of luminaire  $i$ , respectively. This input power  $P_i$  produces luminous flux ( $f_i$ ). Let the illuminance level at work place  $j$  from all luminaires be denoted by  $L_j$ , which can be computed by aggregating illuminance from each luminaire. Then  $L_j$  is represented by




Figure 2. Zoning Strategy for a Typical Share Office.

where  $l_{ij}$  is the illuminance level at work place  $j$  from luminaire  $i$ , which is modeled as

$$l_{ij} = \begin{cases} f_i \frac{4\pi}{\sin^2 \phi_i} \frac{\cos \theta_{ij}}{d_{ij}^2}, & \text{if } \theta_{ij} \leq \phi_i \\ 0, & \text{elsewhere} \end{cases} \quad (3)$$

where  $\phi_i$  is the beam angle of luminaire  $i$  [16, 17].  $\theta_{ij}$  is the angle between the normal to the work place  $j$  and the direction of the luminaire  $i$ , and  $d_{ij}$  is the distance between the work place  $j$  and the luminaire  $i$ . Let  $L_j^r$  denote the required illuminance level for work space  $j$ , which must be guaranteed to be at the center of the corresponding work place. A set of discrete values of  $\phi_i$ 's and a limited range of continuous  $f_i$ 's values that are proportional to the input luminaire power are assumed [18, 19]. Then, an issue of resource control in the LCS to find an optimal pair of  $f_i$ 's values and  $\phi_i$ 's values for efficient LCS operation arises, with an objective of minimizing the total power consumption of luminaires while providing the required illuminance level at each work place.

### 3. Proposed joint power and beam angle control scheme

#### 3.1 Problem formulation

The objective of joint power and beam angle control is to minimize the total power consumption of luminaires with constraints of user satisfaction and

limited range of control parameters. With an assumption that luminous flux is proportional to power, the objective can be changed by minimizing the total flux of the luminaires. Then, an optimization problem  $P_0$  for efficient control of the luminaires is presented as

$$(P_0) \quad \text{Min} \sum_{i=1}^L f_i \quad (4)$$

$$\text{Subject to} \quad \sum_{i=1}^L f_i \frac{4\pi}{\sin^2 \phi_i} \frac{\cos \theta_{ij}}{d_{ij}^2} \geq L_j^r \quad (5)$$

$$f_{\max} \leq f_i \leq f_{\min} \quad (6)$$

$$\phi_i \in \Phi \quad (7)$$

where  $f_{\min}$  and  $f_{\max}$  are the minimum and maximum dimming capabilities, and  $\Phi$  is the set of available beam angles values. Equation 4 is the objective function to minimize the sum flux of luminaires, and Equation 5 shows the constraints for provision of the required illuminance level at each work place. Equations 6 and 7 limit the range of flux and beam angle of each luminary, respectively. For given  $\phi_i$ 's, values,  $P_0$  is a linear program (LP) problem for  $f_i$ 's, which is represented as

$$(P1) \quad \text{Min} \sum_{i=1}^L f_i$$

$$\text{Subject to} \quad \sum_{i=1}^L f_i \alpha_{ij} \geq L_j^r \quad (8)$$

$$f_{\max} \leq f_i \leq f_{\min}$$

$$\phi_i \in \Phi$$

where  $\alpha_{ij}$  replaces  $(4\pi \cos \theta_{ij}) / (d_{ij}^2 \sin^2 \phi_i)$ .

#### 3.2 Algorithm

To solve the lighting control optimization problem, an algorithm is suggested that uses a full search followed by an LP problem. The full search is used to generate unique combinations of discrete  $\phi_i$ 's, and, in this way, a total of  $T$  unique combinations are generated, where  $T=M^L$ , and  $M$  denote the

number of discrete values of  $\phi_i$ 's. At each iteration of full search, P1 is solved for given  $\phi_i$ 's using a CVX tool to obtain the optimal values. Let the optimal  $f_i$ 's and the corresponding  $\phi_i$ 's for the  $k^{th}$  iteration be denoted by  $f_i^{*(k)}$ 's and  $\phi_i^{*(k)}$ 's, respectively. Thus, a total of T  $f_i^{*(k)}$ 's are obtained, among which the  $f_i^{*(k)}$ 's with minimum summation and the corresponding  $\phi_i^{*(k)}$ 's are chosen as the optimal solution. This process is summarized in the algorithm below:

#### Algorithm

$\Pi_k$ : Summation of  $f_i^{*(k)}$ 's for ( $i=1$  to  $L$ )

$f_i^*$ : Optimal luminous flux of  $i^{th}$  luminaire

$\phi_i^*$ : Optimal beam angle of  $i^{th}$  luminaire

$\Omega$ : Iteration Index of optimal solution

$\Psi$ : Minimum  $\Pi_k$

#### Begin

1:  $\Psi = L \cdot f_{max}$

2: **For**  $k=1$  to  $M$

3: Generate combination of  $\phi_i$ 's, ( $i=1$  to  $L$ )

4: Solve P1 using CVX to obtain  $f_i^*$ , ( $i=1$  to  $L$ )

```
cvx_begin
variable f_i(L, 1)
minimize (sum_{i=1}^L f_i)
Subject to
    L_i >= L_i^r
    f_i > f_min
    f_i <= f_max
cvx_end
```

5: **If**  $\Pi_k < \Psi$  **Then**

6: Update  $\Psi$  and  $\Omega$

$\Psi = \Pi_k$

$\Omega = k$

**EndIf**

**EndFor**

7: **For**  $i=1$  to  $L$   
 $f_i^* = f_i^{*(\Omega)}$

$$\phi_i^* = \phi_i^{*(\Omega)}$$

**EndFor**

**End**

#### 4. Performance evaluation

This section provides the performance evaluation of the proposed joint power and beam angle control scheme in comparison with a conventional lighting control scheme by a measure of total luminous flux.




Figure 3. Luminous Flux of Luminaires at Various User Occupancies for the Proposed Scheme and Conventional Scheme.

A light power control scheme with fixed beam angle is considered as the conventional scheme.

An LCS is considered for a  $5m \times 5m \times 4m$  cubic room. The room is divided into 25 regions of space, each of size  $1m \times 1m$ . Four luminaires are considered to be located on the ceiling. The maximum luminous flux of each luminaire is considered to be  $5000lm$ . Two recommended illuminance levels of  $200lx$  and  $400lx$  for normal activities are assumed as the required illuminance levels [20]. The occupants were placed in the square grids in a random manner. It is assumed that  $\phi$  consists of discrete values of beam angle that can be described as  $\phi_i = \Delta \times n$  such that ( $0^\circ < \phi_i \leq 90^\circ$ ), where  $n$  is a positive integer, and  $\Delta$  is the unit step size of the beam angle control. For

example,  $\Phi$  consists of discrete beam angles of  $20^\circ$ ,  $40^\circ$ ,  $60^\circ$  and  $80^\circ$  for a unit step size of  $20^\circ$ .

Figure 3 compares the luminous flux of four luminaires for user occupancy rate of 20%, 40%, 60%, 80%, and 100%, of the proposed scheme and conventional scheme. The proposed scheme adjusts the beam angle of luminaires at the optimal beam angles that satisfy the required illuminance level at each workplace and minimizes the sum of luminous flux of all luminaires. The luminous flux of some luminaires can be smaller in case of a conventional scheme as compared to the proposed scheme at a certain occupancy valve, but the sum of luminous flux of all luminaires is always minimum




Figure 4. Total Luminous Flux of Luminaires at Various User Occupancies for the Proposed Scheme and Conventional Scheme.

In the case of the proposed scheme. In other words, the proposed scheme minimizes the total luminous flux of the luminaires.

Figure 4 compares the total luminous flux of the proposed scheme and the conventional scheme for user occupancy rates of 4~100% unit step size of  $20^\circ$ . The simulations were carried out for 500 iterations; occupants were distributed randomly at each iteration. The average of total luminous flux is computed for comparison. The proposed scheme reduces the total luminous flux of the luminaires and achieves 25% average improvement in lighting energy savings. It is observed that the total luminous flux increases with the increase of user occupancy rate, as well as with the user required illuminance level.

Figure 5 compares the total luminous fluxes of the proposed and conventional schemes for various unit step sizes of  $5^\circ$ ,  $10^\circ$ ,  $15^\circ$  and  $20^\circ$ , where the user required illuminance level is 200lx. The proposed scheme achieves energy savings of 15% on average at various unit step sizes, as shown in Figure 5. It is noted that energy saving in the proposed scheme can be improved by using small  $\Delta$ .




Figure 5. Total Luminous Flux of Luminaires at Various Beam Angle Control Resolutions for the Proposed Scheme and Conventional Scheme.

#### 4. Conclusion

This paper proposed a lighting beam angle control scheme that efficiently minimizes the energy consumption of a lighting system while satisfying the user's lighting requirements. The simulation results show that the proposed scheme can increase energy savings by up to 25% on average compared to the conventional scheme. To further enhance the energy efficiency of LCS, a joint blind angle control for efficient utilization of available daylight will be considered in future works.

#### Acknowledgements

This work was supported by the Basic Science Research Program through the National Research Foundation of Korea (NRF) funded by the Ministry of Education, Science and Technology (2011-0005439).

#### References

- [1] Key World Energy Statistics, International Energy Agency (online). Available from: <http://www.iea.org/publications/freepublications/publication/name,31287,en.html>



- [2] L. Halonen et al., "Lighting energy in buildings" in L. Halonen et al., (eds) *Guidebook on Energy Efficient Electric Lighting for Buildings*, Espoo, Finland: Aalto University School of Science and Technology, 2010, pp. 19–36.
- [3] J. Diaz et al., *CAN Bus Embedded System for Lighting Network Applications*. In 51st Midwest Symposium on Circuit and System, Knoxville, TN, 2008, pp. 531- 534.
- [4] T. P. Huynh et al., *Energy-aware Wireless Sensor Network with Ambient Intelligence for Smart LED Lighting System Control*. In 37th Annual Conference on IEEE Industrial Electronics Society, Melbourne, Australia, 2011, pp. 2923 – 2928.
- [5] A. A. N. Kumaar et al., "Intelligent Lighting System Using Wireless Sensor Networks". *International Journal of Adhoc, Sensor & Ubiquitous Computing (IJASUC)*, Vol.1, No.4, December 2010, pp. 17-27.
- [6] F. Rubinstein and S. Treado, *Standardizing Communication between Lighting Control Devices: a role for IEEE P1451*. In Conference record of the 2003 IEEE Industry Applications Conference 38th IAS Annual Meeting, Salt Lake City, UT, USA, 2003, pp. 805-811.
- [7] Y. Wen et al., *Towards Embedded Wireless-Networked Intelligent Daylighting Systems for Commercial Buildings*. In IEEE International Conference on Sensor Networks, Ubiquitous, and Trustworthy Computing - Vol 2, 2006.
- [8] J. Granderson et al., *Towards Demand-Responsive Intelligent Lighting With Wireless Sensing and Actuation*. Proceeding of Annual Conference of Illuminating Engineering Society of North America (IESNA), Tampa, FL, 2004.
- [9] M. S. Pan et al., "A WSN-Based Intelligent Light Control System Considering User Activities and Profiles". *IEEE Sensors Journal*, Vol. 10, No.10, October 2008, pp. 1710- 1721.
- [10] M. S. Pan et al., *Design and Implementation of a WSN-based Intelligent Light Control System*. In 28th International Conference on Distributed Computing Systems Workshops, Beijing, 2008. Pp. 531-534.
- [11] K. Ono et al., *An Optimization Algorithm to Provide Individual Illuminance using LED Ceiling Lights and Verification at Actual Office*. In IEEE International Conference on Systems, Man, and Cybernetics (SMC), Anchorage, Alaska, 2011, pp. 644-648.
- [12] T. Hiroyasu et al., *Intelligent Lighting Control User Interface through Design of Illuminance Distribution*. In Ninth International Conference on Intelligent Systems Design and Applications, Pisa, 2009, pp. 714-719.
- [13] Y. J. Wen and A. M. Agogino, *Wireless networked lighting Systems for Optimizing Energy Savings and User Satisfaction*. In IEEE Wireless Hive Networks Conference, Austin, TX, 2008, pp. 1-7.
- [14] C. A. Castillo et al., "Digitally Controlled Integrated Electronic Ballast with Dimming and Power Factor Correction Features", *Journal of Applied Research and Technology*, Vol. 8, No 3, 2010, pp. 295–309.
- [15] LED Waves, *Beam-Angle Adjustable PAR-30 LED Light Bulb* (online). Available from: <http://www.ledwaves.com>.
- [16] *Antenna Introduction Basics* (online). Available from: <http://www.tscm.com/antennas.pdf.x>
- [17] A. Ryer, "The Light Measurement Handbook" Peabody, International Light Technologies, 1997, pp. 28-40.
- [18] C. Poissonnet, *LED Light Fixtures and Selection Criteria for Underwater Video Inspections*. In OCEANS 2009, MTS/IEEE Biloxi–Marine Technology for Our Future: Global and Local Challenges, 2009, pp. 1-7.
- [19] *Light Bulb Beam Angles*, EagleLight's LED University (online). Available from: <http://www.eaglelight.com>
- [20] Provision 3011 of KSA (Korean Standards Association), *Recommended levels of illumination*, 1991.